



STEVE SISOLAK
Governor

STATE OF NEVADA
DEPARTMENT OF TRANSPORTATION

1263 S. Stewart Street
Carson City, Nevada 89712

Kristina L. Swallow, P.E., Director

In Reply Refer to:

April 4, 2022

SAM DUNNAM
T.Y. UN
4050 DEAN MARTIN
LAS VEGAS, NV 89103

TECHNICAL DRAINAGE STUDY
RAINBOW CARWASH
SOUTH OF OWENS AND NELLIS
BLVD
CLARK COUNTY

Mr. Dunnam:

The Nevada Department of Transportation (NDOT) Hydraulics Division has received and reviewed the following document(s) for the above-referenced project.

Document:	Dated:
TDS	3/16/2022
Plans	3/16/2022
Drainage form	3/16/2022

The drainage design information presented in the reviewed document(s):

	is acceptable in concept. Final Hydraulic Division approval will be based on review of final design documents submitted with the NDOT Right-Of-Way Occupancy Permit application that must be submitted for this project.
x	is acceptable in concept. Final Hydraulic Division approval will be based on review of final design documents submitted with the NDOT Right-Of-Way Occupancy Permit application that must be submitted for this project. The following comments should be addressed with the permit application:
	must be supplemented or modified to satisfy the following comment(s) before preliminary Hydraulic Division approval can be granted:

1. It was unclear in the plans provided if the discharge from the car wash bay is captured and routed into the sanitary sewer system. Please provide this detail when you submit your permit documents.

All submittals regarding this project must be forwarded through (or copied to) the local NDOT District permitting office. All pertinent drainage design documents (including those previously submitted for preliminary review) must be submitted to the local NDOT District permitting office with the Right-of-Way Occupancy Permit Application. All plans and reports must be signed and stamped by a Nevada registered civil engineer.

No liability is assumed by the Department in performing this review. Verification and acceptance of all background information, design data and conclusions is the responsibility of the consulting engineer.

Please call me at (775) 888-7816 or email me at dlake@dot.nv.gov should you have any questions.

Sincerely,

DocuSigned by:

9858763DEC9B400...

David Lake, P.E., M.S.
Senior Hydraulic Engineer

cc: Mario Gomez, P.E., District I Engineer
Charles Molisee, District I Permits
Mike Alameda, Headquarters Right-of-Way
James Ragan, District I Permits
Abid Sulahria, P.E., District I Assistant District Engineer
Martin Strganac, P.E., District I Assistant District Engineer