



**LAS VEGAS
CITY COUNCIL**

CAROLYN G. GOODMAN
Mayor

BRIAN KNUDSEN
Mayor Pro Tem

CEDRIC CREAR

VICTORIA SEAMAN

OLIVIA DÍAZ

FRANCIS ALLEN-PALENSKE

NANCY E. BRUNE

MIKE JANSSEN
City Manager

DEPARTMENT OF
COMMUNITY DEVELOPMENT

SETH T. FLOYD

DIRECTOR

CITY HALL

495 S. MAIN ST., 3RD FLOOR
LAS VEGAS, NV 89101

702.229.6011 | VOICE
711 | TTY



cityoflasvegas | lasvegasnevada.gov

September 11, 2024

Betty Shervorski
The Howard Hughes Company, LLC
10845 Griffith Peak Drive, Suite160
Las Vegas, Nevada 89135

RE: 24-0345-TMP1
PLANNING COMMISSION MEETING OF SEPTEMBER 10, 2024

Dear Applicant:

The Planning Commission at a regular meeting held on *September 10, 2024* voted to **APPROVE** the following Land Use Entitlement project request FOR A 387-LOT SINGLE FAMILY RESIDENTIAL ATTACHED AND DETACHED SUBDIVISION on 88.54 acres at the northwest corner of Lake Mead Boulevard and Park Drift Trail (APNs 137-21-513-001, 137-15-411-002 and 137-22-111-006), P-C (Planned Community) Zone [AA (Active Adult) Summerlin Special Land Use Designation], Ward 2 (Seaman).

This approval is subject to the following conditions:

Planning

1. Approval of the Tentative Map shall be for no more than four (4) years. If a Final Map is not recorded on all or a portion of the area embraced by the Tentative Map within four (4) years of the approval of the Tentative Map, this action is void.
2. Street names must be provided in accordance with the City's Street Naming Regulations.
3. In conjunction with creation, declaration and recordation of the subject common-interest community, and prior to recordation of the Covenants, Codes and Restrictions ("CC&R"), or conveyance of any unit within the community, the Developer is required to record a Declaration of Private Maintenance Requirements ("DPMR") as a covenant on all associated properties, and on behalf of all current and future property owners. The DPMR is to include a listing of all privately owned and/or maintained infrastructure improvements, along with assignment of maintenance responsibility for each to the common interest community or the respective individual property owners, and is to provide a brief description of the required level of maintenance for privately maintained components. The DPMR must be reviewed and approved by the City of Las Vegas Department of Field Operations prior to recordation, and must include a statement

that all properties within the community are subject to assessment for all associated costs should private maintenance obligations not be met, and the City of Las Vegas be required to provide for said maintenance. Also, the CC&R are to include a statement of obligation of compliance with the DPMR. Following recordation, the Developer is to submit copies of the recorded DPMR and CC&R documents to the City of Las Vegas Department of Field Operations.

4. Sign and record a deed restriction with language determined to be satisfactory by the City Attorney which restricts the use of the site to an age-restricted community for those persons 55 years of age or older, to the full extent of the law.
5. All development is subject to the conditions of City Departments and State Subdivision Statutes.

Public Works

6. Private streets must be granted and labeled on the Final Map for this site as Public Utility Easements (P.U.E.), Public Sewer Easements, and Public Drainage Easements to be privately maintained by the Homeowner's Association.
7. Grant a minimum 60-foot wide Public Sewer and Public Drainage Easement by separate document to be privately maintained for the public sewer and storm drain within the existing Summerlin Common Element "F" adjacent to the subdivision entrance on Sandstone Drive. The Public Sewer and Public Drainage Easement (per separate document) shall be recorded prior to submitting Mylar plans or Mylar subdivision Maps. The recorded document number shall be required on the plans where the easement is called out prior to issuing final Mylar approval for Sewer.
8. No walls, signs, lights, parking area, buildings or other structures, or permanent landscaping having a mature height of greater than 3-feet shall be placed anywhere in any public sewer easement or in the vehicle ingress or egress pathways to such easements.
9. Design of horizontal and vertical distance separations for public sewer and flood control infrastructure must meet the City of Las Vegas' design criteria prior to the issuance of permits for this site, unless otherwise allowed by the City Engineer. This may require streets to be wider than what is shown on the approved Tentative Map.
10. All landscaping and private improvements installed with this project shall be situated and maintained so as to not create sight visibility obstructions for vehicular traffic at all development access drives and abutting street intersections.

11. Prior to the submittal of construction drawings for this site, submit a pedestrian circulation plan to identify nearby pedestrian attractors and recommend measures to accommodate pedestrians, such as but not limited to pedestrian access, crosswalk, pedestrian activated flashers and temporary sidewalks. Comply with the recommendation of the approved pedestrian circulation plan.
12. A Drainage Plan and Technical Drainage Study must be submitted to and approved by the Department of Public Works prior to the issuance of any building or grading permits or submittal of any construction drawings, whichever may occur first. Provide and improve all drainageways recommended in the approved drainage plan/study. The developer of this site shall be responsible to construct such neighborhood or local drainage facility improvements as are recommended by the City of Las Vegas Neighborhood Drainage Studies and approved Drainage Plan/Study concurrent with development of this site.
13. As per Unified Development Code (UDC) 19.16.060.G, all requirements must be complied with or such future compliance must be guaranteed by an approved performance security method in accordance with UDC sections 19.02.130.
14. The approval of all Public Works related improvements shown on this Tentative Map is in concept only. Specific design and construction details relating to size, type and/or alignment of improvements, including but not limited to street, sewer and drainage improvements, shall be resolved prior to approval of the construction plans by the City. No deviations from adopted City Standards shall be allowed unless specific written approval for such is received from the City Engineer prior to the recordation of a Final Map or the approval of subdivision-related construction plans, whichever may occur first. Approval of this Tentative Map does not constitute approval of any deviations. If such approval cannot be obtained, a revised Tentative Map must be submitted showing elimination of such deviations.

Fire & Rescue

15. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.

This action by the Planning Commission on September 10, 2024 is final unless a written appeal is filed with the City Clerk within seven days of the date of the Planning Commission's decision as allowed by code or there is a review action filed by the City Council within the same time period. For additional information on appeals or review requests submitted please access <https://www.lasvegasnevada.gov/Business/Permits-Licenses/Building-Permits/Permit-Application-Status>, or contact the Department of Community Development at 702.229.6301 after September 18, 2024. No building permits or business licenses related to these items shall be issued prior to the expiration of the required ten day waiting period, or until any filed appeal is resolved pursuant to LVMC Title 19.18.

24-0345-TMP1 - Page Four
September 11, 2024

Sincerely,

A handwritten signature in black ink, appearing to read "Nicole Eddowes". The signature is fluid and cursive, with the first name "Nicole" written in a larger, more prominent script than the last name "Eddowes".

Nicole Eddowes
Community Development Coordinator
Case Planning Division

NE:jr

cc:

Scott Anderson
Taylor Morrison
1980 Festival Plaza Drive, Suite 500
Las Vegas, Nevada 89135

Amber Dolce
RCI Engineering
500 South Rancho Drive, Suite 17
Las Vegas, Nevada 89106