

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM		DATE: November 5, 2024
TO: Land Development Services Department of Community Development – Building & Safety Division		FROM: Tyler Key Flood Control Engineering Associate Department of Public Works
SUBJECT:	Drainage Study for:	COPIES TO:
	Summerlin Village 19 Charleston Modern	Toll Brothers
Cross Streets:	Charleston Blvd. & Plaza Centre Dr.	RCI Engineering
File Number:	F:\Depot\DSMemos\DS5813A.doc	Bart Anderson, P.E., DevCo
Parcel Number:	164-02-510-007	CCPW
Zoning Action:		
FEMA Flood Zone	YES	NO X
Proposed Storm Drain	YES	NO X

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	10/28/2024	11/5/2024	See Comments Below	\$400	5991740: \$400
			TOTAL FEES (LDDRS):	\$400	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

X	is approved subject to conformance to all City standards and the following conditions: must be resubmitted or supplemented including the following:
	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

- Sanitary sewer may be provided by the City of Las Vegas, please contact City Sanitary Sewer Planning at 229-6541 to determine sewer service requirements immediately to avoid any potential delays in the development process.
- City of Las Vegas Flood Control** staff has reviewed the Technical Drainage Study, including the addenda for the subject development “**Summerlin Village 19 Charleston Modern**” within the jurisdiction of **Clark County**. **City of Las Vegas** concurs with the acceptance of the drainage study by the **Clark County**. The review of this project was limited to issues of flood control significance to the **City of Las Vegas**.

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

- 1st Submittal DS and Plans (for first and original submittal);
- 2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
TJK

T/R/S: T21S/R59E/S2
AREA