

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM			DATE: 11/25/2024		
TO: Land Development Services Department of Community Development – Building & Safety Division			FROM: Albert Sung, P.E. Flood Control Project Engineer Department of Public Works		
SUBJECT:		Drainage Study for:		COPIES TO:	
Ann & Rebecca				Westwood Professional Services	
Cross Streets:	Ann Road & Rebecca Road		Sequoia Ann Rd JV LLC		
File Number:	F:\Depot\DSMemos\DS05809A.doc		Bart Anderson, P.E., DevCo		
Parcel Number:	125-26-403-014		CCRFCD		
Zoning Action:	24-0269-TMP1				
FEMA Flood Zone	YES	NO	X		
Proposed Storm Drain	YES	NO	X		

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	10/9/2024	10/22/2024	See Comments Below	\$400.00	5965978 : \$400
2 nd Submittal	11/6/2024	11/25/2024	See Comments Below	\$400.00	6011147 : \$400
TOTAL FEES (LDDRS):				\$800.00	----

REMARKS:

The Drainage Study for the subject project has been reviewed and:

	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
X	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

1. The site is adjacent to or crosses an existing or proposed Clark County Regional Flood Control District (CCRFCD) master planned facility. Therefore, CCRFCD concurrence is required prior to final approval of the drainage study.

Please note that effective March 15, 2019, the CCRFCD adopted new requirements for drainage study concurrence submittal. Follow the link below for specific guidance.

<http://qustfront.ccrfcd.org/LandDev/LandDev.aspx>

2. Revise cross section '4' on sheet D-1. It is incorrect. The proposed swale in Common Element 'B' is lower than the proposed pads on the east side and lower than the existing pads on the west side.

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

1st Submittal DS and Plans (for first and original submittal);

2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
HDR/OK/SF/JRT

T/R/S: T19S/R60E/S26
AREA G-26