



Department of Public Works

500 S Grand Central Pky • Box 554000 • Las Vegas NV 89155-4000
 (702) 455-6000 • Fax (702) 455-6040

Denis Cederburg, P.E., Director • E-Mail: dlc@ClarkCountyNV.gov



Drainage Study Concurrence Letter

Date: July 11, 2023
Firm: Actus
Engineer: Roshan Poudel, P.E.
Address: 3283 East Warm Springs Road, Suite 300, Las Vegas, NV 89120
Phone: (702) 586-9296
Fax:
E-mail: roshan.poudel@actus-nv.com

Subject: Technical Drainage Study for La Mancha & Gaisford
Location: NWC of la Mancha & Gaisford
APN: 126-25-401-004 & -005
Sec, Township, Range: S25, T19S, R59E
Flood Zone & Panel: Zone X, 1750E, dated September 27, 2002
Application Number: PW23-14694

Submittals	Date Received	Date Returned	Reviewer	Miscellaneous
Technical	06/26/2023	07/11/2023	BC	
Addendum 1	06/26/2023	07/11/2023	BC	
Addendum 2	06/26/2026	07/11/2023	BC	

Concurrence Required: (Must be obtained prior to permit issuance)	Reason Concurrence is Required
Boulder City	Adjacent to or Impacts Jurisdiction
City of Mesquite	Adjacent to or Impacts Jurisdiction
City of Henderson	Adjacent to or Impacts Jurisdiction
City of Las Vegas	Adjacent to or Impacts Jurisdiction
City of North Las Vegas	Adjacent to or Impacts Jurisdiction
Nevada Department of Transportation	Adjacent to or Impacts NDOT Facility
Union Pacific Rail Road	Adjacent to or Impacts a UPRR Facility
US Army Corps of Engineers	Impacts a USACE Facility
Clark County Regional Flood Control District	Regional Significance, Adjacent to or Impacts CCRFCD MPU Facility or in a SFHA

The referenced **Technical Drainage Study** has been reviewed and is accepted as complying with minimum improvement standards. As set forth in the subject drainage study, the following measures will be taken to mitigate flood hazards.

The site shall be graded with respect to drainage as shown on "**La Mancha and Gaisford**", grading plan sheets C1 thru C15, signed and sealed by Darryl C. Lattimore, P.E., on June 5, 2023.

Check appropriate conditions

	Retaining/screen wall combination may be in excess of current Clark County Unified Development Code, Chapter 30.64.050.
	A FEMA Elevation Certificate, completed by a licensed surveyor, must be submitted to and approved by CCPW Development Review Plan Check prior to the issuance of Certificates of Occupancy for those structures.
X	MyIars of the grading plan must be submitted to the CCPW Development Review Plan Check for approval signatures prior to map recordation (residential) or permit issuance (commercial).
	An administrative variance to allow the finished floor elevation(s) to be set below the current Clark County criteria must be approved. The finished floor variance must be submitted to CCPW Development Review front counter after drainage study approval and prior to offsite final review.
	The grading plan will be reviewed by the Building Office Operations Division to ensure compliance with the ADA access requirements. Revisions to the grading plan may be required if the site accessibility design does not comply with the requirements set forth in the Accessibility Chapter of the Clark County Building Code.
X	The plans show work is proposed outside of the project boundary. Notarized written permission must be obtained prior to grading plan approval.
X	Right-of-way dedication must be verified.
	Any previously approved drainage easements that are not being used must be vacated.
	<i>Per Regional Flood Control District policies and Procedures manual, Section VIII. D. 13. Uniform Regulations for the Control of Drainage</i> , the Engineer of Record shall provide As-Built plans or record drawings to the District after completion and final inspection of such privately installed flood control facilities that have regional flood control significance.
	Structural calculations are required. The structural calculations, plans, and details must be approved prior to "Offsite" submittal and prior to CCRFCD submittal, if applicable.
X	Plan revisions can be found on the red-lined plans and must be addressed.
	Prepare drainage easement documents as shown on the grading plans.

Additional Conditions:


1. The above-referenced project is located within the **City of Las Vegas** adjacent to Clark County unincorporated areas. The drainage study was submitted to Clark County for concurrence on June 26, 2023. In addition, the County has received the City of Las Vegas acceptance letter dated June 21, 2023 for the Technical Drainage Study DS5651C.
2. The County concurs with the acceptance of this Drainage Study by the City of Las Vegas. Please note that the County's review of this development is limited to drainage issues significant to Clark County unincorporated areas.
3. Ensure Clark County signature blocks and notes are on plans.
4. The plans as proposed show a shared footing and wall between parcel 126-25-401-001 and the project site. Either revise the footing to be entirely on the project site in City of Las Vegas or the footings may need to be permitted by Clark County Building Department.
5. Review the grades as proposed for Gaisford at the sag vertical curve. Proposed grades will result in ponding in Clark County. Revise grading as necessary.

The County's review is solely based on the information submitted by the Engineer of Record. The County's review is strictly limited to compliance with minimum County Codes and Standards. The Engineer of Record is responsible for researching and addressing situations that may require designs above and beyond the minimum codes for issues of public safety and impacts to upstream, downstream and adjacent properties. The County assumes no liability for information, data, designs or conclusions of the Engineer of Record.

If you have any questions about the provided comments, please contact the reviewer* below.



*Brian Churchill, P.E., CFM
Senior Civil Engineer
Development Review
Brian.Churchill@ClarkCountyNV.gov



W. Layne Weber, P.E., CFM
Principal Engineer
Development Review
wlweber@ClarkCountyNV.gov

cc: Albert Sung, P.E., City of Las Vegas