



**LAS VEGAS
CITY COUNCIL**

SHELLEY BERKLEY
Mayor

BRIAN KNUDSEN
Mayor Pro Tem

VICTORIA SEAMAN
OLIVIA DIAZ

FRANCIS ALLEN-PALENSKE

NANCY E. BRUNE

SHONDRA
SUMMERS-ARMSTRONG

MIKE JANSSEN
City Manager

DEPARTMENT OF
COMMUNITY DEVELOPMENT

SETH T. FLOYD
DIRECTOR

CITY HALL

495 S. MAIN ST., 3RD FLOOR
LAS VEGAS, NV 89101
702.229.6011 | VOICE
711 | TTY



cityoflasvegas
lasvegasnevada.gov

June 11, 2025

Brian Walsh
The Howard Hughes Company, LLC
1700 South Pavilion Center Drive, #250
Las Vegas, Nevada 89135

**RE: 25-0188-TMP1
PLANNING COMMISSION MEETING OF JUNE 10, 2025**

Dear Applicant:

The Planning Commission at a regular meeting held on *June 10, 2025* voted to **APPROVE** the following Land Use Entitlement project request FOR A PROPOSED 45-LOT SINGLE-FAMILY RESIDENTIAL SUBDIVISION on 50.19 acres on the west side of the Park Drift Trail alignment, approximately 2,500 feet north of the intersection with Twilight Run Drive and Lake Mead Boulevard (APNs 137-16-811-001 and 137-15-310-002), P-C (Planned Community) Zone [SF1 (Single Family Detached) Summerlin Special Land Use Designation], Ward 2 (Seaman).

This approval is subject to the following conditions:

Planning

1. Approval of the Tentative Map shall be for no more than four (4) years. If a Final Map is not recorded on all or a portion of the area embraced by the Tentative Map within four (4) years of the approval of the Tentative Map, this action is void.
2. Street names must be provided in accordance with the City's Street Naming Regulations.
3. All development is subject to the conditions of City Departments and State Subdivision Statutes.

Public Works

4. Private streets must be granted and labeled on the Final Map for this site as Public Utility Easements (P.U.E.), Public Sewer Easements, and Public Drainage Easements to be privately maintained by the Homeowner's Association. Additionally, all Homeowner's Association common lot elements and any private improvements in the public right-of-way authorized by an Encroachment License Agreement shall be the maintenance responsibility of the Homeowner's Association.

If the Homeowner's Association fails to perform any private maintenance obligation, then the individual property owners within the subdivision shall be jointly and severally liable for any and all City expenses that may be incurred to perform any private maintenance obligations.

5. Grant a minimum 30-foot wide Public Sewer and Drainage Easement by separate document to be privately maintained for the public sewer and storm drain within existing Summerlin Common Element "T" adjacent to Park Drift Trail. The Public Sewer and Drainage Easement (per separate document) shall be recorded prior to submitting Mylar plans or Mylar subdivision Maps. The recorded document number shall be required on the plans where the easement is called out prior to issuing final Mylar approval for Sewer.
6. Prior to the mapping of any lots or civil mylar approvals, submit a Waste Water Master Plan (WWMP) update with updated calculations for the new amount of proposed units, as the number of proposed lots is greater than what was proposed on the WWMP.
7. Design of horizontal and vertical distance separations for public sewer and flood control infrastructure must meet the City of Las Vegas' design criteria prior to the issuance of permits for this site, unless otherwise allowed by the City Engineer. This may require streets to be wider than what is shown on the approved Tentative Map.
8. No walls, signs, lights, parking area, buildings or other structures, or permanent landscaping having a mature height of greater than 3 feet shall be placed anywhere in any Public Sewer Easement or in the vehicle ingress or egress pathways to such easements.
9. All landscaping and private improvements installed with this project shall be situated and maintained so as to not create sight visibility obstructions for vehicular traffic at all development access drives and abutting street intersections.
10. Queues for the gated entrance shall not extend into the public right-of-way as a result of the gated operations on this site. Additionally, the gate shall have a bypass lane for residents.
11. An update to the previously approved Drainage Plan and Technical Drainage Study must be submitted to and approved by the Department of Public Works prior to submittal of any construction drawings or the issuance of any building or grading permits, whichever may occur first. Provide and improve all drainageways recommended in the approved drainage study update.
12. As per Unified Development Code (UDC) 19.16.060.G, all requirements must be complied with or such future compliance must be guaranteed by an approved performance security method in accordance with UDC sections 19.02.130.


13. The approval of all Public Works related improvements shown on this Tentative Map is in concept only. Specific design and construction details relating to size, type and/or alignment of improvements, including but not limited to street, sewer and drainage improvements, shall be resolved prior to approval of the construction plans by the City. No deviations from adopted City Standards shall be allowed unless specific written approval for such is received from the City Engineer prior to the recordation of a Final Map or the approval of subdivision-related construction plans, whichever may occur first. Approval of this Tentative Map does not constitute approval of any deviations. If such approval cannot be obtained, a revised Tentative Map must be submitted showing elimination of such deviations.

Fire & Rescue

14. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.

This action by the Planning Commission on **June 10, 2025** is final unless a written appeal is filed with the City Clerk within seven days of the date of the Planning Commission's decision as allowed by code or there is a review action filed by the City Council within the same time period. For additional information on appeals or review requests submitted please access <https://www.lasvegasnevada.gov/Business/Permits-Licenses/Building-Permits/Permit-Application-Status>, or contact the Department of Community Development at 702.229.6301 after **June 17, 2025**. No building permits or business licenses related to these items shall be issued prior to the expiration of the required seven day waiting period, or until any filed appeal is resolved pursuant to LVMC Title 19.18.

Sincerely,



Nicole Eddowes
Community Development Coordinator
Case Planning Division

NE:bp

cc:

April Chapman
The Howard Hughes Company, LLC
1700 South Pavilion Center Drive, #250
Las Vegas, Nevada 89135

Hailey Shinton
GCW, INC
1555 South Rainbow Boulevard, Las Vegas, Nevada 89146