

CITY OF LAS VEGAS INTER-OFFICE MEMORANDUM			DATE: August 4, 2025
TO: Land Development Services Department of Community Development – Building & Safety Division			FROM: Tyler Key Flood Control Engr. Associate Department of Public Works
SUBJECT:		Drainage Study for:	COPIES TO:
		Summerlin Village 30A Parcel C – Mass Grading	GCW, Inc.
Cross Streets:	SWC of Mountain Run Dr. & Park Drift Tr.		Howard Hughes Company
File Number:	F:\Depot\DSMemos\DS5863C.doc		Lucien Paet, P.E., DevCo
Parcel Number:	137-21-711-002		CCRFCD
Zoning Action:	N/A		
FEMA Flood Zone	YES	NO	X
Proposed Storm Drain	YES	NO	X

HISTORY	DATE RECEIVED	DATE REVIEWED	COMMENTS	REVIEW FEES	FEES PAID Payment Trn #
1 st Submittal	5/7/2025	5/21/2025	Not Approved	\$400.00	6234431: \$400
2 nd Submittal	6/17/2025	6/25/2025	Cond. Approved	\$400.00	6283609: \$400
3 rd Submittal	7/21/2025	8/4/2025	See Comments Below	\$100.00	6325308: \$100
TOTAL FEES (LDDRS):				\$900.00	----

3rd Submittal: Update #1 to move the 15' wide ditch along the western boundary to onsite.

REMARKS:

The Drainage Study for the subject project has been reviewed and:

	is approved subject to conformance to all City standards and the following conditions:
	must be resubmitted or supplemented including the following:
X	is conditionally approved subject to Clark County Regional Flood Control District concurrence.
	is conditionally approved subject to Clark County Public Works Department concurrence.

Comments remaining from previous submittals:

1. The project proposes to mass grade with temporary drainage facilities for erosion protection. Prior to final plan approval the developer must complete a maintenance and liability agreement for the interim drainage improvements (off-site berms or channels) and post a minimum maintenance bond of \$50,000 or 50-percent of the construction cost for the improvements, whichever is greater. If the interim drainage improvements are bonded per phase, each phase must post a minimum maintenance bond of \$50,000 or 50-percent of the construction cost, whichever is greater, for each phase. The engineer must submit an estimate of the quantities for constructing the facility and an exhibit that adequately shows the location and limits of the drainage facility to *City of Las Vegas Flood Control* for approval. Once the drainage study is conditionally approved, the engineer should contact the City's Land Development Section (229-6371) to begin the agreement process.

In order for the maintenance bond to be released in the future, a drainage update / letter will be required to justify that the offsite berms / channels are no longer necessary and can be removed.

2. The site is adjacent to or crosses an existing or proposed *Clark County Regional Flood Control District* (CCRFCD) master planned facility. Therefore, CCRFCD concurrence is required prior to final approval of the drainage study.

Please note that effective March 15, 2019, the CCRFCD adopted new requirements for drainage study concurrence submittal. Follow the link below for specific guidance.

<http://gustfront.ccrfcd.org/LandDev/LandDev.aspx>

***** The City of Las Vegas Flood Control is standardizing the file naming of drainage studies and plans during the digitizing process. When saving the project files in the CD or thumb drive, please follow the system below:**

If drainage study only contains one combined file, use the following naming convention in Document Title:

1st Submittal DS and Plans (for first and original submittal);

2nd Submittal DS and Plans (for second submittal (addendum #1)) etc.

If drainage study contains multiple files, use the following naming convention in Document Title:

1st Submittal DS (for the report of the drainage study)

1st Submittal Plan 1 (could be the drainage condition maps)

1st Submittal Plan 2 (could be the improvement plans) etc.

NOTE: Please be advised that all land surface area disturbances over 1 acre or any area adjacent to a water way must submit to the *Nevada Division of Environmental Protection* a "Notice of Intent" to discharge that certifies a stormwater pollution prevention plan has been developed and is maintained on site; for inclusion in the Stormwater General Permit No. NVR100000. A phased construction unit in a contiguous subdivision is considered under construction until all stripped or disturbed surface areas have been covered by paving, building construction or planting. For more information, including forms and applications see <http://ndep.nv.gov/bwpc/storm01.htm> or call (775) 687-9429.

NOTE: Any future changes to the proposed design (or design assumptions) as outlined in the approved drainage study and attached preliminary grading plan which affect drainage must be addressed in a Drainage Study Update and accepted by the *City of Las Vegas Flood Control Section*. Additionally, final approval of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, the *City of Las Vegas* reserves the right to require additional conditions and/or submission and acceptance of a complete drainage study update prior to further construction of a project.

END OF REMARKS
AYS/TJK

T/R/S: T20S/R59E/21
AREA K-21