

Mayor
Pamela A. Goynes-Brown

City Manager
Micaela Moore

Council Members
Isaac E. Barron
Ruth Garcia-Anderson
Scott Black
Richard J. Cherchio



Your Community of Choice

Department of Public Works – Mike Hudgeons, P.E.

2250 Las Vegas Boulevard, North · Suite 200 · North Las Vegas, Nevada 89030

Telephone: (702) 633-1919 · Fax: (702) 649-4696 · TDD: (800) 326-6868

www.cityofnorthlasvegas.com

September 17, 2025

Mailed Via: E-mail

Andrew Whittaker, P.E.
RCI Engineering
500 South Rancho Drive
Las Vegas, NV 89106

Re: **Update #1 to the TDS for Hylo Park South Texas**

(CNLV No. 184-2025)

Dear Mr. Whittaker

The City of North Las Vegas (CNLV) has reviewed the above referenced Technical Drainage Study Update received on August 27, 2025, and found them to meet the minimum accepted standards for a Technical Drainage Study. This acceptance is contingent upon the following condition(s):

1. Concurrence must be obtained from Clark County Regional Flood Control District (CCRFCD) prior to final approval of the Civil Improvement Plans since the site is adjacent to an existing or proposed CCRFCD master planned facility. A copy of this study and all the addenda must be submitted to CCRFCD once approved by CNLV.
2. Concurrence must be obtained from City of Las Vegas Public Works (CLVPW) prior to approval of the Civil Improvement Plans since the site is adjacent to City of Las Vegas jurisdiction boundary. A copy of this study and all the addenda must be submitted to CLVPW once approved by CNLV.
3. Please note that the site needs to be protected under the worst-case storm event.

Please be advised that all land surface area disturbances over 1 acre and/or adjacent to a water way must submit a "Notice of Intent" to discharge to the Nevada Division of Environmental Protection, which certifies that a storm water pollution prevention plan has been developed and is maintained on site. For more information, including forms and applications, see <http://ndep.nv.gov/bwpc/storm01.htm>.

Acceptance of this drainage study update does not imply approval of the improvement plans associated with the drainage for this site. A detailed review of the improvement plans will be performed by staff during the improvement plan review process.

Any future changes in the proposed design (or design assumptions) as outlined in the approved drainage study which affect drainage must be addressed in a drainage study update and accepted by the CNLV Development and Flood Control Division. Additionally, conditional acceptance of a drainage study is valid for a period of one (1) year. If the proposed construction has not been completed in that time period, CNLV reserves the right to require additional conditions and/or submission and acceptance of another complete drainage study update prior to further construction of the project.

The City of North Las Vegas, its officials, or employees assume no liability for information, data, calculations and conclusions presented by the consulting engineers. We, therefore, make no warranties, either expressed or implied, in conducting this review. If you have any questions concerning this matter, please contact me at (702)-633-1254.

Sincerely,

A handwritten signature in blue ink, appearing to be 'Simon Luk', written in a cursive style.

Simon Luk, P.E., M.S.
Engineering Associate
Development and Flood Control Division
Department of Public Works