



LAS VEGAS CITY COUNCIL

OSCAR B. GOODMAN
MAYOR

GARY REESE
MAYOR PRO TEM

LARRY BROWN
STEVE WOLFSON
LOIS TARKANIAN
STEVEN D. ROSS
RICKI Y. BARLOW

DOUGLAS A. SELBY
CITY MANAGER



CITY OF LAS VEGAS
400 STEWART AVENUE
LAS VEGAS, NEVADA 89101

VOICE 702.229.6011
TDD 702.386.9108
www.lasvegasnevada.gov

February 21, 2008

Mr. Lucero Zapata-Paez
Cornucopia Investments
10300 West Charleston Boulevard, Suite #13-413
Las Vegas, Nevada 89135

RE: SDR-25995 – SITE DEVELOPMENT PLAN REVIEW
CITY COUNCIL MEETING OF FEBRUARY 20, 2008
RELATED TO ZON-25992

Dear Mr. Zapata-Paez:

The City Council at a regular meeting held February 20, 2008 APPROVED the request for a Site Development Plan Review FOR A PROPOSED 9,000 SQUARE FOOT OFFICE DEVELOPMENT on 0.94 acres adjacent to the south side of Vegas Drive, approximately 580 feet west of Pyramid Drive (APN 139-30-501-001), R-1 (Single Family Residential) Zone [PROPOSED: C-1 (Limited Commercial) Zone].. The Notice of Final Action was filed with the Las Vegas City Clerk on February 21, 2008. This approval is subject to:

Planning & Development

1. Approval of and conformance to the Conditions of Approval for Rezoning (ZON-25992) shall be required.
2. This approval shall be void two years from the date of final approval, unless a building permit has been issued for the principal building on the site. An Extension of Time may be filed for consideration by the City of Las Vegas.
3. All development shall be in conformance with the site plan, landscape plan, and building elevations, date stamped 12/11/07, except as amended by conditions herein.
4. A revised site plan shall be submitted to and approved by the Planning and Development Department, prior to the time application is made for a building permit, to remove the proposed eight-foot decorative block wall between this site and the site to the east.
5. A technical landscape plan, signed and sealed by a Registered Architect, Landscape Architect, Residential Designer or Civil Engineer, must be submitted prior to or at the same time application is made for a building permit. A permanent underground sprinkler system is required, and shall be permanently maintained in a satisfactory manner; the landscape plan shall

include irrigation specifications. The technical landscape plan shall include the following changes from the conceptual landscape plan:

- A minimum of ten (10) 24-inch box trees shall be planted within the perimeter landscape planter along the south property line, in compliance with the requirements of Title 19.12.
 - A minimum of eight (8) 24-inch box trees shall be planted within the provided parking lot landscape islands and at the end of parking rows. In addition, a minimum of four (4) five-gallon shrubs shall be planted for each required tree.
 - A minimum of four (4) five-gallon shrubs shall be planted for each required tree within perimeter landscape buffers.
6. Pre-planting and post-planting landscape inspections are required to ensure the appropriate plant material, location, size of planters, and landscape plans are being utilized. The Planning and Development Department must be contacted to schedule an inspection prior to the start of the landscape installation and after the landscape installation is completed. A certificate of occupancy will not be issued or the final inspection will not be approved until the landscape inspections have been completed.
 7. Reflective glazing at the pedestrian level is prohibited. Glazing above the pedestrian level shall be limited to a maximum reflectance rating of 22% (as defined by the National Institute of Standards and Technology).
 8. All mechanical equipment, air conditioners and trash areas shall be fully screened in views from the abutting streets.
 9. All utility boxes exceeding 27 cubic feet in size shall meet the standards of LVMC Title 19.12.040.
 10. Parking lot lighting standards shall be no more than 30 feet in height and shall utilize downward-directed lights with full cut-off luminaries. Lighting on the exterior of buildings shall be shielded and shall be downward-directed. Non-residential property lighting shall be directed away from residential property or screened, and shall not create fugitive lighting on adjacent properties.
 11. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
 12. Prior to the submittal of a building permit application, the applicant shall meet with Planning and Development Department staff to develop a comprehensive address plan for the subject site. A copy of the approved address plan shall be submitted with any future building permit applications related to the site.

13. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.


Public Works

14. Construct all incomplete half-street improvements on Vegas Drive adjacent to this site concurrent with development of this site.
15. Install a median island restricting the east driveway to right in right out only operation or provide a driveway turning analysis that demonstrates this driveway will operate safely.
16. Unless otherwise allowed by the City Engineer, construct sidewalk on at least one side of all access drives connecting this site to the adjacent public streets concurrent with development of this site. The connecting sidewalk shall extend from the sidewalk on the public street to the first intersection of the on-site roadway network and shall be terminated on-site with a handicap ramp.
17. Submit an application to the Land Development section of the Department of Public Works for a deviation from Standard Drawing #222a for the driveway accessing this site from Vegas Drive.
18. All private improvements and landscaping installed with this project shall be situated and maintained so as to not create sight visibility obstructions for vehicular traffic at all development access drives and abutting street intersections.
19. Contact the City Engineer's Office at 229-6272 to coordinate the development of this project with the Coran Rancho Vegas Sewer Rehabilitation project and the Owens Avenue System project and any other public improvement projects adjacent to this site. Comply with the recommendations of the City Engineer.
20. A Traffic Impact Analysis must be submitted to and approved by the Department of Public Works prior to the issuance of any building or grading permits, submittal of any construction drawings. Comply with the recommendations of the approved Traffic Impact Analysis prior to occupancy of the site. The Traffic Impact Analysis shall also include a section addressing Standard Drawings #234.1 #234.2 and #234.3 to determine additional right-of-way requirements for bus turnouts adjacent to this site, if any; dedicate all areas recommended by the approved Traffic Impact Analysis. All additional rights of way required by Standard Drawing #201.1 for exclusive right turn lanes and dual left turn lanes shall be dedicated prior to or concurrent with the commencement of on site development activities unless specifically noted as not required in the approved Traffic Impact Analysis. Phased compliance will be allowed if recommended by the approved Traffic Impact Analysis. No recommendation of the approved Traffic Impact Analysis, nor compliance therewith, shall be deemed to modify or eliminate any condition of approval imposed by the Planning Commission or the City Council on the development of this site.

Mr. Lucero Zapata-Paez
SDR-25995 – Page Four
February 21, 2008

21. Meet with the Flood Control Section of the Department of Public Works for assistance with establishing finished floor elevations and drainage patterns for this site prior to submittal of construction plans or the issuance of any building or grading permits, whichever may occur first. Provide and improve all drainageways recommended by the Flood Control Section.

Sincerely,

A handwritten signature in black ink, appearing to read "Angela Crolli". The signature is fluid and cursive, with the first name "Angela" written in a larger, more prominent script than the last name "Crolli".

Angela Crolli
Deputy City Clerk II for
Beverly K. Bridges, CMC, City Clerk

cc: Planning and Development Dept.
Development Coordination-DPW
Dept. of Fire Services