

# PLANNING & DEVELOPMENT



DEVELOPMENT SERVICES CENTER

731 S. Fourth Street  
Las Vegas, NV 89101

TTY 702-386-9108

Voice:

Administration 229-6353

Comp Planning 229-6022

Current Planning 229-6301

[www.lasvegasnevada.gov](http://www.lasvegasnevada.gov)



064218

October 6, 2006

Ms. Ella  
McKinney Construction  
400 West Owens  
Las Vegas, Nevada 89106

***RE: SDR-16178 - SITE DEVELOPMENT PLAN REVIEW***

Dear Ms. Ella:

Your request for a Site Development Plan Review FOR THE PROPOSED CONVERSION OF A 2,826 SQUARE FOOT RESIDENCE AND 375 SQUARE FOOT CASITA TO A PLACE OF WORSHIP on 0.85 acres at 4901 Jean Avenue (APN 138-13-801-061), R-E (Residence Estates) Zone, Ward 5 (Weekly), was considered by the Planning Commission on October 5, 2006.

The Planning Commission voted to recommend ***APPROVAL*** of your request, subject to the following:

**Planning and Development**

1. This approval shall be void two years from the date of final approval, unless a building permit has been issued for the principal building on the site. An Extension of Time may be filed for consideration by the City of Las Vegas.
2. All development shall be in conformance with the site plan, landscape plan, and building elevations, date stamped 09/06/06, except as amended by conditions herein.
3. A revised site plan shall be submitted to and approved by the Planning and Development Department, prior to the time application is made for building permit to reflect the provision of eight 24 inch box trees within the center landscape planter.
4. Pre-planting and post-planting landscape inspections are required to ensure the appropriate plant material, location, size of planters, and landscape plans are being utilized. The Planning and Development Department must be contacted to schedule an inspection prior to the start of the landscape installation and after the landscape installation is completed. A certificate of occupancy will not be issued or the final inspection will not be approved until the landscape inspections have been completed.

Mayor  
Oscar B. Goodman

City Council  
Gary Reese  
(Mayor Pro Tem)  
Larry Brown  
Lawrence Weekly  
Steve Wolfson  
Lois Tarkanian  
Steven D. Ross

City Manager  
Douglas A. Selby



5. Reflective glazing at the pedestrian level is prohibited. Glazing above the pedestrian level shall be limited to a maximum reflectance rating of 22% (as defined by the National Institute of Standards and Technology).
6. All mechanical equipment, air conditioners and trash areas shall be fully screened in views from the abutting streets.
7. Parking lot lighting standards shall be no more than 30 feet in height and shall utilize downward-directed lights with full cut-off luminaires. Lighting on the exterior of buildings shall be shielded and shall be downward-directed. Non-residential property lighting shall be directed away from residential property or screened, and shall not create fugitive lighting on adjacent properties.
8. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
9. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.

**Public Works**


10. Dedicate an additional 10 feet of right-of-way for a total half-street width of 30 feet on Jean Avenue adjacent to this site prior to the issuance of any permits.
11. Construct half-street improvements, including appropriate transition paving, on Jean Avenue adjacent to this site concurrent with development of this site. All existing paving damaged or removed by this development shall be restored at its original location and to its original width concurrent with development of this site. Extend all required underground utilities, such as electrical, telephone, etc., located within public rights-of-way, past the boundaries of this site prior to construction of hard surfacing (asphalt or concrete).
12. Extend the existing sewer line in Jean Avenue past the western boundary of this site at a depth and location acceptable to the Collection System Planning Section of the Department of Public Works. Provide public sewer easements for all public sewers not located within existing public street right-of-way prior to the issuance of any permits as required by the Department of Public Works. Improvement Drawings submitted to the City for review shall not be approved for construction until all required public sewer easements necessary to connect this site to the existing public sewer system have been granted to the City.

Ms. Ella  
SDR-16178 - Page Three  
October 6, 2006

13. Meet with the Flood Control Section of the Department of Public Works for assistance with establishing finished floor elevations and drainage patterns for this site prior to submittal of construction plans, the issuance of any building or grading permits or the submittal of a map for this site, whichever may occur first. Provide and improve all drainage ways as recommended.
14. Meet with the Fire Protection Engineering Section of the Department of Fire Services to discuss fire requirements for the proposed use of this facility.

This item will be considered by the City Council on **November 1, 2006**, at 1:00 P.M. in the Council Chambers of City Hall, 400 Stewart Avenue, Las Vegas, Nevada. ***The Council requires that you or your representative be present at this meeting.*** If you or your representative chooses not to attend, the City Council may act in your absence without your input.

Sincerely,



Douglas J. Rankin, Acting Current Planning Manager  
Planning and Development Department  
Current Planning Division

DJR:dm

cc: Mr. John Arnold  
Mt. Zion Church  
4901 Jean Avenue  
Las Vegas, Nevada 89108