



040913



MAYOR
OSCAR B. GOODMAN

CITY COUNCIL
GARY REESE
(MAYOR PRO-TEM)
LARRY BROWN
LYNETTE B. McDONALD
LAWRENCE WEEKLY
MICHAEL MACK
JANET MONCRIEF

CITY MANAGER
DOUGLAS A. SELBY

January 8, 2004

Mr. Mark Howard
Sunrise Mountainview Hospital
3100 North Tenaya Way
Las Vegas, Nevada 89106

RE: SDR-3273 - SITE DEVELOPMENT PLAN REVIEW
CITY COUNCIL MEETING OF JANUARY 7, 2004

Dear Mr. Howard:

The City Council at a regular meeting held January 7, 2004 APPROVED the request for a Site Development Plan Review FOR A PROPOSED 220,000 SQUARE-FOOT, FOUR-STORY PARKING STRUCTURE on 28.10 acres adjacent to the southeast corner of Tenaya Way and Cheyenne Avenue (APN: 138-15-510-005), C-PB (Planned Business Park) Zone. The Notice of Final Action was filed with the Las Vegas City Clerk on January 8, 2004. This approval is subject to:

Planning and Development

1. The site plan shall be revised and approved by Planning and Development Department, prior to the time application is made for a building permit, to reflect the relocation of handicap accessible parking spaces to the area currently utilized as valet parking. The existing 64 valet parking spaces may be relocated to another portion of the parking lot located in a less utilized, low turnover area further from the main entrance of the hospital and medical office building.
2. This Site Development Plan Review shall expire two years from date of final approval unless it is exercised or an Extension of Time is granted by the City Council.
3. All development shall be in conformance with the site plan and building elevations, except as amended by conditions herein.
4. The proposed building material finish and color scheme shall match the existing buildings on-site.
5. Prior to the submittal of a building permit, the applicant shall meet with Planning and Development Department staff to develop a comprehensive address plan for the subject site. A copy of the approved address plan shall be submitted with any future building permit applications related to the site.

CITY OF LAS VEGAS
400 STEWART AVENUE
LAS VEGAS, NEVADA 89101

VOICE 702.229.6011
TTY 702.386.9108
www.ci.las-vegas.nv.us

6. Landscaping and a permanent underground sprinkler system shall be installed as required by the Planning Commission or City Council and shall be permanently maintained in a satisfactory manner. [Failure to properly maintain required landscaping and underground sprinkler systems shall be cause for revocation of a business license.]
7. A landscaping plan must be submitted prior to or at the same time application is made for a building permit.
8. All mechanical equipment, air conditioners and trash areas shall be fully screened in views from the abutting streets and neighboring properties.
9. Parking lot lighting standards shall be no more than 20 feet in height and shall utilize 'shoe-box' fixtures and downward-directed lights. Wallpack lighting shall utilize 'shoe-box' fixtures and downward-directed lights on the proposed building. Non-residential property lighting shall be directed away from residential property or screened, and shall not create fugitive lighting on adjacent properties.
10. All utility boxes exceeding 27 cubic feet in size shall meet the standards of Municipal Code Section 19.12.050.
11. Any proposed property line wall shall be a decorative block wall, with at least 20 percent contrasting materials. Wall heights shall be measured from the side of the fence with the least vertical exposure above the finished grade, unless otherwise stipulated.
12. Any property line wall shall be a decorative block wall, with at least 20 percent contrasting materials. Wall heights shall be measured from the side of the fence with the least vertical exposure above the finished grade, unless otherwise stipulated.
13. All City Code requirements and design standards of all City departments must be satisfied.

Public Works

14. Dedicate an additional 10 feet of right-of-way and radii as appropriate along Cheyenne Avenue.
15. Remove all substandard public street improvements, if any, adjacent to this site and replace with new improvements meeting current City Standards concurrent with on-site development activities.
16. Meet with the Traffic Engineering Representative in Land Development for assistance in the possible redesign of the proposed driveway access, on site circulation and parking lot layout prior to the submittal of any construction plans or the issuance of any permits, whichever may occur first. Driveways shall be designed, located and constructed in accordance with Standard Drawing #222A.

Mr. Mark Howard
SDR-3273 – Page Three
January 8, 2004

17. A Drainage Plan and Technical Drainage Study must be submitted to and approved by the Department of Public Works prior to the issuance of any building or grading permits or submittal of any construction drawings, whichever may occur first. Provide and improve all drainageways recommended in the approved drainage plan/study. The developer of this site shall be responsible to construct such neighborhood or local drainage facility improvements as are recommended by the City of Las Vegas Neighborhood Drainage Studies and approved Drainage Plan/Study concurrent with development of this site. In lieu of constructing improvements, in whole or in part, the developer may agree to contribute monies for the construction of neighborhood or local drainage improvements, the amount of such monies shall be determined by the approved Drainage Plan/Study and shall be contributed prior to the issuance of any building or grading permits, whichever may occur first, if allowed by the City Engineer.
18. Site development to comply with all applicable conditions of approval for Zoning Reclassification Z-68-85 and all other subsequent site-related actions.

Sincerely,



Angela Crolli
Deputy City Clerk II for
Barbara Jo Ronemus, City Clerk

cc: Planning and Development Dept.
Development Coordination-DPW
Dept. Of Fire Services