




012182

CITY of LAS VEGAS



MAYOR
JAN LAVERTY JONES

COUNCILMEN
ARNIE ADAMSEN
MICHAEL J. MCDONALD
GARY REESE
LARRY BROWN

CITY MANAGER
VIRGINIA VALENTINE

December 10, 1998

Ms. Dusty Dickens
Mr. Richard Horton
Clark County School District
4828 South Pearl Street
Las Vegas, Nevada 89121

RE: Z-78-98 - REZONING

Dear Applicant:

The City Council at a regular meeting held December 7, 1998 APPROVED the request for a Rezoning on property located at 4291 West Pennwood Avenue, From: R-E (Residence Estates) To: C-V (Civic), TO CONFORM ZONING TO THE SITE'S SCHOOL USE AND TO PROVIDE FOR THE CONSTRUCTION OF ADDITIONAL CLASSROOMS, A GYM, AND A CONCESSION STAND, ALL COMPRISING 36,322 SQUARE FEET, Size: 39.90 Acres. The Notice of Final Action was filed with the Las Vegas City Clerk on December 8, 1998. This approval is subject to:

1. Dedicate 40 feet of right-of-way adjacent to this site for Pennwood Avenue, 40 feet for Arville Street, 30 feet for Wing Street, and 30 feet for Sirius Street. Also, dedicate a 25 foot radius on the southeast corner of Pennwood Avenue and Arville Street, 20 feet for the southwest corner of Pennwood Avenue and Wing Street, 15 feet for the northwest corner of Wing Street and Sirius Avenue, and 20 feet for the northeast corner of Sirius Avenue and Arville Street prior to the issuance of any permits as required by the Department of Public Works.
2. A Resolution of Intent.
3. All development shall be in conformance with the plot plan and building elevations.
4. All mechanical equipment, air conditioners and trash areas shall be screened from view from the abutting streets (excluding single family development).
5. All City Code requirements and design standards of all City departments must be satisfied.



400 E. STEWART AVENUE • LAS VEGAS, NEVADA 89101-2986


(702) 229-6011 (VOICE) • (702) 386-9108 (TDD)

www.ci.las-vegas.nv.us (WEBSITE)

Ms. Dusty Dickens
Mr. Richard Horton
Clark County School District
Z-78-98 – Page Two
December 10, 1998

6. Parking and driveway plans must be approved by the Traffic Engineer prior to the issuance of any permits.
7. All damage to the existing street improvements resulting from this development must be repaired as required by the Department of Public Works.
8. Remove all substandard public street improvements and all unused driveway cuts adjacent to this site, if any, and replace with new improvements meeting current City standards prior to occupancy of this site as required by the Department of Public Works.
9. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
10. Where new water mains are extended along streets and fire hydrants are not needed for protection of structures, hydrants shall be spaced at a maximum distance of 1,000 feet to provide for transportation hazards.
11. Provide plans showing accessible exterior routes from public transportation stops, accessible parking, passenger loading zones and public sidewalks to the accessible building entrance(s) with submittal of plans for building permits as required by the Planning and Development Department. Accessible routes shall have running slopes and cross slopes in accordance with the applicable code.

Sincerely,



BARBARA JO RONEMUS
City Clerk

/ac

cc: Planning and Development Dept.
Development Coordination-DPW
Dept. Of Fire Services
Land Development Services