



**LAS VEGAS
CITY COUNCIL**

CAROLYN G. GOODMAN
Mayor

MICHELE FIORE
Mayor Pro Tem

STAVROS S. ANTHONY

CEDRIC CREAR

BRIAN KNUDSEN

VICTORIA SEAMAN

OLIVIA DIAZ

SCOTT D. ADAMS
City Manager

September 19, 2019

Drea 357, LLC
1528 Castle Crest Drive
Las Vegas, Nevada 89117

**RE: SDR-76578 [PRJ-76322] - SITE DEVELOPMENT PLAN REVIEW
RELATED TO GPA-76573, ZON-76574 AND VAR-76577
CITY COUNCIL MEETING OF SEPTEMBER 18, 2019**

Dear Applicant:

The City Council at a regular meeting held on September 18, 2019 voted to **APPROVE** your request for a Site Development Plan Review FOR A HEAVY MACHINERY AND EQUIPMENT STORAGE DEVELOPMENT on 0.84 acres at 1622 and 1630 Sunset Drive (APNs 139-19-812-012 and 013), C-2 (General Commercial) Zone [PROPOSED: M (Industrial)], Ward 5 (Crear) [PRJ-76322].

This approval is subject to the following conditions:

Planning

1. Approval of and conformance to the Conditions of Approval for General Plan Amendment (GPA-76573), Rezoning (ZON-76574), and Variance (VAR-76577) shall be required, if approved.
2. This approval shall be void two years from the date of final approval, unless exercised pursuant to the provisions of LVMC Title 19.16. An Extension of Time may be filed for consideration by the City of Las Vegas.
3. All development shall be in conformance with the site plan, date stamped 05/30/19, except as amended by conditions herein.
4. All necessary building permits shall be obtained and final inspections shall be completed in compliance with Title 19 and all codes as required by the Department of Building and Safety.
5. 1622 Sunset Drive (APN 139-19-812-012) and 1630 Sunset Drive (APN 139-19-812-013) are to be consolidated prior to the issue of a building permit.

DEPARTMENT OF PLANNING

ROBERT SUMMERFIELD
DIRECTOR

**DEVELOPMENT
SERVICES CENTER**

333 N. RANCHO DRIVE
3RD FLOOR
LAS VEGAS, NV 89106
702.229.6301 | VOICE
702.474.7463 | FAX
711 | TTY



cityoflasvegas
lasvegasnevada.gov

6. These Conditions of Approval shall be affixed to the cover sheet of any plan set submitted for building permit.
7. A technical landscape plan, signed and sealed by a Registered Architect, Landscape Architect, Residential Designer or Civil Engineer, must be submitted prior to or at the same time application is made for a building permit. A permanent underground sprinkler system is required, and shall be permanently maintained in a satisfactory manner; the landscape plan shall include irrigation specifications. Installed landscaping shall not impede visibility of any traffic control device. The technical landscape plan shall be designed in accordance with the standard planting requirement of Title 19.08.040(F).
8. A fully operational fire protection system, including fire apparatus roads, fire hydrants and water supply, shall be installed and shall be functioning prior to construction of any combustible structures.
9. All City Code requirements and design standards of all City Departments must be satisfied, except as modified herein.

Public Works

10. Construct all incomplete half-street improvements on Sunset Drive to meet City standards concurrent with on-site development activities.
11. Landscape and maintain all unimproved right-of-way adjacent to this site. All landscaping and private improvements installed with this project shall be situated and maintained so as to not create sight visibility obstructions for vehicular traffic at all development access drives and abutting street intersections.
12. Submit a License Agreement for landscaping and private improvements in the Sunset Drive public right-of-way, if any, prior to the issuance of permits for these improvements. The applicant must carry an insurance policy for the term of the License Agreement and add the City of Las Vegas as an additionally insured entity on this insurance policy. If requested by the City, the applicant shall remove property within the public right-of-way at the applicant's expense pursuant to the terms of the City's License Agreement. The installation and maintenance of all private improvements in the public right of way shall be the responsibility of the applicant and any successors in interest to the property and assigns pursuant to the terms of the License Agreement. Coordinate all requirements for the License Agreement with the Land Development Section of the Department of Building and Safety (702-229-4836).

13. Abandon the existing temporary individual sewage disposal septic system prior to the issuance of any permits.
14. Meet with the Flood Control Section of the Department of Public Works for assistance with establishing finished floor elevations and drainage paths for this site prior to submittal of construction plans, the issuance of any building or grading permits, whichever may occur first. Provide and improve all drainage ways as recommended.

The Notice of Final Action was filed with the Las Vegas City Clerk on September 19, 2019.

Sincerely,



Robert Summerfield, AICP[®]
Director
Department of Planning

RTS:PL:clb

cc: Mr. Dennis Meservy
Mistteerose Holding, LLC
601 East Charleston Boulevard, Suite #101
Las Vegas, Nevada 89104

Mr. Ricki Barlow
LV Access & Associates
3172 North Rainbow Boulevard, Suite #202
Las Vegas, Nevada 89108